



# 产品认证证书

证书编号: CQC13123101002

## 申请人名称及地址

上海辰竹仪表有限公司  
上海市漕河泾开发区松江高科技园莘砖公路518号5幢702室

## 制造商名称及地址

上海辰竹仪表有限公司  
上海市漕河泾开发区松江高科技园莘砖公路518号5幢702室

## 生产企业名称及地址

上海辰竹仪表有限公司 (V017515)  
上海市松江区民益路201号6号楼七层, 八层

## 产品名称和系列、规格、型号

低压配电系统的电涌保护器

CZLB-20/320/1P, CZLB-20/320/2P, CZLB-20/320/3P, CZLB-20/320/4P, CZLB-40/440/1P, CZLB-40/440/2P, CZLB-40/440/3P, CZLB-40/440/4P; 详见参数附件

## 产品标准和技术要求

GB 18802.1-2011

## 认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462111-2012认证规则的要求, 特发此证。

发证日期: 2013年11月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_



# 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0049972



# PRODUCT CERTIFICATE

No.: CQC13123101002

## NAME AND ADDRESS OF THE APPLICANT

Shanghai Chenzhu Instrumentation Co.,Ltd.  
Room 702, Building 5, No.518 Xinzhuan Road, Songjiang Hi-tech Park, Caohejing Development Zone,  
Shanghai, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Shanghai Chenzhu Instrumentation Co.,Ltd.  
Room 702, Building 5, No.518 Xinzhuan Road, Songjiang Hi-tech Park, Caohejing Development Zone,  
Shanghai, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Shanghai Chenzhu Instrumentation Co.,Ltd. (V017515)  
7/F, 8/F, Building 6, No.201 Minyi Road, Songjiang District, Shanghai, P.R.China

## NAME, MODEL AND SPECIFICATION

Surge Protective Device Connected to Low-voltage Power Distribution Systems  
CZLB-20/320/1P, CZLB-20/320/2P, CZLB-20/320/3P, CZLB-20/320/4P, CZLB-40/440/1P, CZLB-40/440/2P, CZLB-  
40/440/3P, CZLB-40/440/4P; See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 18802.1-2011

## CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules  
CQC11-462111-2012.

Date of issue: Nov.07,2013

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing  
certification body until the expiry date.

President:

  
Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0049972



# 产品认证证书

附录:

证书编号: CQC13123101002

第 1 页 共 1 页

纸号: 49972

II 类试验 (T2):

| 型号             | 保护模式   | $I_{\max}$<br>(kA) | $I_n$ (kA) | $U_c$<br>(V) | $U_p$ (kV) | 组合方式 |
|----------------|--------|--------------------|------------|--------------|------------|------|
| CZLB-20/320/1P | /      | 20                 | 10         | 320          | 1.5        | 1P   |
| CZLB-20/320/2P | L/N-PE | 20                 | 10         | 320          | 1.5        | 2P   |
| CZLB-20/320/3P | L-PE   | 20                 | 10         | 320          | 1.5        | 3P   |
| CZLB-20/320/4P | L/N-PE | 20                 | 10         | 320          | 1.5        | 4P   |
| CZLB-40/440/1P | /      | 40                 | 20         | 440          | 2.2        | 1P   |
| CZLB-40/440/2P | L/N-PE | 40                 | 20         | 440          | 2.2        | 2P   |
| CZLB-40/440/3P | L-PE   | 40                 | 20         | 440          | 2.2        | 3P   |
| CZLB-40/440/4P | L/N-PE | 40                 | 20         | 440          | 2.2        | 4P   |

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>