



产品认证证书

证书编号: CQC13123101433

申请人名称及地址

上海辰竹仪表有限公司
上海市漕河泾开发区松江高科技园莘砖公路518号5幢702室

制造商名称及地址

上海辰竹仪表有限公司
上海市漕河泾开发区松江高科技园莘砖公路518号5幢702室

生产企业名称及地址

上海辰竹仪表有限公司 (V017515)
上海市松江区民益路201号6号楼七层, 八层

产品名称和系列、规格、型号

电涌保护器

CZLBX-48、CZLBX-48-3、CZLBX-48-4; 详见参数附件

产品标准和技术要求

GB 18802.1-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462111-2012认证规则的要求, 特发此证。

发证日期: 2014年12月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2013年11月13日

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0066401



PRODUCT CERTIFICATE

No.: CQC13123101433

NAME AND ADDRESS OF THE APPLICANT

Shanghai Chenzhu Instrumentation Co.,Ltd.
Room 702, Building 5, No.518 Xinzhuan Road,Songjiang Hi-tech Park, Caohejing Development Zone,
Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai Chenzhu Instrumentation Co.,Ltd.
Room 702, Building 5, No.518 Xinzhuan Road, Songjiang Hi-tech Park, Caohejing Development Zone,
Shanghai, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai Chenzhu Instrumentation Co.,Ltd. (V017515)
7/F, 8/F, Building 6, No.201 Minyi Road, Songjiang District, Shanghai, P.R.China

NAME, MODEL AND SPECIFICATION

Surge Protective Device

CZLBX-48、 CZLBX-48-3、 CZLBX-48-4;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 18802.1-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules
CQC11-462111-2012.

Date of issue: Dec.17,2014

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Date of original certification: Nov.13,2013

President: _____

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0066401



产品认证证书

附录:

证书编号: CQC13123101433

第 1 页 共 1 页

纸号: 66401

型号	U_1 (V)	传输特性	保护模式	试验类别	电压保护水平 U_2 (V)
CZLBX-48	48V DC	电容<15pF	<input checked="" type="checkbox"/> 线-地/X-C	C2: 10kV/5kA	600
CZLBX-48-3	48V DC	电容<15pF	<input checked="" type="checkbox"/> 线-地/X-C	C2: 10kV/5kA	600
CZLBX-48-4	48V DC	电容<15pF	<input checked="" type="checkbox"/> 线-地/X-C	C2: 10kV/5kA	600

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>