



防爆合格证

证号: GYB15.1344

由 上海辰竹仪表有限公司

制造的产品:

(地址: 上海市漕河泾开发区新经济园民益路201号6号厂房7、8层)

名称 浪涌保护安全栅

型号规格 LBGS8077-EX

防爆标志 [Ex ia Ga] IIC

产品标准 Q/IROL 3-2014、Q/IROL 1-2012

图样编号 LBGS8077-EX.0-3.2

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.4-2010、GB 3836.20-2010 标准, 特颁发此证。

本证书有效期: 2015年5月28日至2020年5月27日

备注 1. 安全使用注意事项见使用说明书。

2. 最高电压 (U_m): 250V。

3. 本安电气参数 (端子 9-10-11):

$U_0 = 8.5V$; $I_0 = 95mA$; $P_0 = 0.209W$; $C_0 = 6.5\mu F$; $L_0 = 2.3mH$; $C_i = 0\mu F$; $L_i = 0.4mH$

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一五年五月二十八日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO.GYB15.1344

This is to certify that the product

Surge Protective Safety Barrier

manufactured by **Shanghai Chenzhu Instrument Co.,Ltd**

(Address:7-8th Floor,Building 6,201 Minyi Road,Caohejing Development Zone,New Economic Park, shanghai.)

which model is **LBGS8077-EX**

Ex marking **[Ex ia Ga] IIC**

product standard **Q/IROL 3-2014**

drawing number **LBGS8077-EX.0-3.2**

has been inspected and certified by NEPSI, and that it conforms to **GB 3836.1-2010,GB 3836.4-2010,GB 3836.20-2010**

This Approval shall remain in force until **2020.05.27**

Remarks **1.Conditions for safe use are specified in the instructions.
2.Maximum voltage (Um): 250V
3.Intrinsic safety parameters(Terminals 9-10-11):
Uo=85V; Io=95mA; Po=0.209W; Co=6.5μF; Lo=23mH; Ci=0μF; Li=0.4mH**

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date **2015.05.28**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580