防爆合格证

证 号：GYB16.1341

由 上海辰竹仪表有限公司 制造的产品：

（地址： 上海市漕河泾开发区新经济园民益路201号6幢701、703室）

名 称 隔离式安全栅

型 号 规 格 GS8523-EX、GS8523-EX.I

防 爆 标 志 [Ex ia Ga] IIC

产 品 标 准 Q/IROL 3-2014

图 样 编 号 GS8523-EX.0 Rev.4.1、GS8523-EX.I.0 Rev.4.1

经图样及技术文件的审查和样品检验，确认上述产品符合 GB 3836.1-2010、GB 3836.4-2010、GB 3836.20-2010 标准，特颁发此证。

本证书有效期： 2016 年 5 月 18 日至 2021 年 5 月 17 日

备 注 1. 安全使用注意事项见使用说明书。
2. 最高电压（Um）：250V。
3. 本安电气参数（端子 7-8）：
Uo = 25V; Io = 140mA; Po = 875mW; Co = 0.11μF; Lo = 1.5mH; Ci = 0μF; Li = 0.36μH

站 长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一六年五月十八日

本证书仅对与认可文件和样品一致的产品有效。

地址：上海市漕宝路103号 网址：www.nepsi.org.cn 电话：+86 21 64368180
邮编：200233 Email:info@nepsi.org.cn 传真：+86 21 64844580

EXPLOSION PROTECTION
CERTIFICATE OF CONFORMITY

Cert NO.GYB16.1341

This is to certify that the product

Isolated barrier

manufactured by Shanghai Chenzhu Instrument Co.,Ltd
(Address:Room 701, 703, Building 6, 201 Minyi Road, Caohejing Development Zone, New Economic Park, shanghai)

which model is GS8523-EX，GS8523-EX.I

Ex marking [Ex ia Ga] IIC

product standard Q/IROL 3-2014

drawing number GS8523-EX.0 Rev.4.1、GS8523-EX.I.0 Rev.4.1

has been inspected and certified by NEPSI, and that it conforms to GB 3836.1-2010,GB 3836.4-2010,GB 3836.20-2010

This Approval shall remain in force until 2021.05.17

Remarks
1.Conditions for safe use are specified in the instructions.
2.Maximum voltage (Um): 250V
3.Intrinsic safety parameters (Terminals 7-8):
Uo = 25V; Io = 140mA; Po = 875mW; Co = 0.11μF; Lo = 1.5mH; Ci = 0μF; Li = 0.36μH

Director

National Supervision and Inspection Centre for Explosion Protection and Safety of Instrumentation

Issued Date 2016.05.18

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

http://www.nepsi.org.cn
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580